

SYMBOLS LIST APARTMENT D/B APARTMENT SYSTEMS CUPBOARD SINGLE SOCKET 13A design@wkkarchitects.com www.wkkarchitects.com DOUBLE SOCKET 13A Д tel: +44(0) 1403259405 45A D/P COOKER CONTROL UNIT Structural Engineering: 20A D/P ISOLATOR 13A FUSE SPUR UNIT Ō MECHANICAL EQUIPMENT REQUIRING POWER SUPPLY INTERNET OUTLET (STRUCTURE CABLING) RJ45 CAT6A C/W UTP CABLING TELEPHONE OUTLET (RJ45 CAT6A STRUCTURE CABLE) VIDEO INTERCOM Α ACCESS DOOR PIR (PASSIVE INFRARED SENSOR) Logos\JPG_WHITE.JPG BURGLAR ALARM KEYPAD MANUAL BREAK GLASS AND FIRE ALARM BELL Mechanical & Energy Engineering: Electrical Engineering: FIREMAN EMERGENCY EVACUATION COMMUNICATION SYSTEM YPANTIS TV OUTLET $\mathbb{Q} \mathbb{D}$ WATER LEAKAGE DETECTOR (ROPE TYPE) ELECTRIC TOWEL RAIL HEATER MAGNETIC DOOR CONTACT Interior Designer: MAGNETIC DOOR CONTACT CONNECTED TO RECEPTION CCTV SECURITY MONITOR SCREEN .\Logos\SIDE TO SIDE LOGO.jpg

GENERAL NOTES

ENGINEER.

1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECTURAL & STRUCTURAL 2. THIS DRAWING IS TO BE READ IN

Local Structural Engineering:

P.O.Box 21653, 1511 Nicosia Tel. +357 22 741300 Fax +357 22 741400 email: cantoniou@cybarco.com

.\Logos\EVRIPIDOU.jpg

.\Logos\logo-2015.jpg

P.O.Box 53240 3301 Limassol Tel. 25-875732 Mob. 99-645105 Fax 25-581680 email: sinka@cytanet.com.cy Web: www.elemecconsult.com

Fire Engineering:

- CONJUNCTION WITH ALL RELEVANT BUILDING SERVICES DRAWINGS & THE RELEVANT SECTIONS OF THE SPECIFICATIONS & SCHEDULES. 3. THIS DRAWING IS NOT SCALED.
- 4. ALL DIMENSIONS ARE IN MM UNLESS OTHERWISE STATED.
 5. THE DRAWING DOES NOT INDICATE THE PRESENCE OF ALL SERVICES AND IS TO BE READ IN CONJUNCTION WITH THE MECHANICAL SERVICES SPECIFICATION AND DRAWINGS.
- 6. ANY DISCREPANCY BETWEEN ELEMEC-GBC M&E DESIGN DOCUMENTATION; ARCHITECTS LAYOUTS AND STATUTORY REGULATIONS REQUIRE IMMEDIATE NOTIFICATION TO THE
- 7. THE ELECTRICAL INSTALLATIONS SHALL BE CARRIED OUT IN ACCORDANCE WITH THE IET WIRING REGULATIONS BS 7671: 2008 (17th EDITION, 3rd AMENDMENT 2015, TO BE IN FORCE IN CYPRUS IN 2017), THE ELECTRICITY AUTHORITY OF CYPRUS AND THE ELECTROMECHANICAL SERVICES DEPARTMENT OF THE MINISTRY OF COMMUNICATIONS AND WORK STATUTORY REGULATIONS, ALL IN ACCORDANCE TO THE RELEVANT EN,
- CEN, CENELEC (EU) CYS, IEC REGULATIONS AND ISO QUALITY STANDARDS. POWER SUPPLIES & CONTROLS FOR THE HVAC FAN COIL UNITS & U/F HEATING
- WILL BE AS PER MECHANICAL DESIGNS.
 ONLY THE APARTMENTS AIR
 CONDITIONING SYSTEM SHALL BE
 REMOTELY OPERATED FROM THE APARTMENT'S SMART TOUCH SCREEN.
- 9. PROVIDE SEPARATE 20mm PVC EMPTY CONDUIT FROM EACH BEDROOM, LOUNGE, KITCHEN AND BATHROOMS THROUGH TO THE SYSTEM CUPBOARDS FOR THE LOUD SPEAKERS AND VOLUME CONTROL OF THE AUDIO AND VISION SYSTEMS
- 10. ALL ELECTRICAL CABLING AND WIRING OF THE APARTMENTS LIGHTING, POWER AND SYSTEMS OUTLETS AND CONTROL DEVICES SHALL BE INSTALLED IN UPVC CONDUITS THROUGH THE FALSE CEILINGS AND PARTITION WALLS OR BRICK WALLS AND NOT THROUGH THE FLOOR SCREEDS.

 11. PROVISION FOR FACADE LIGHTING 24 V
- FROM FACADE D/B (THE LIGHTING CONTROL SHALL BE FROM THE COMMONS CENTRAL LIGHTING CONTROL).
 THE FINAL DESIGN SHALL BE PROVIDED FOLLOWING THE LIGHTING DESIGNERS

n Checke
C. SINKA
0111111

TRILOGY Limassol Seafront

Scale: 1:100@ A1 Issued:

LH Limassol Seafront Ltd. Agias Fylaxeos, 118 Christabel **House Limassol 3087 Cyprus**

NORTH TOWER
PROPOSED SMALL POWER & SYSTEMS LEVEL 35

status: suitability description:

revision : revision description :