

SYMBOLS LIST

- SMART HOME PUSH BUTTONS  
-LIGHTING SWITCHING AND DIMMING  
-RAISE/LOWER CURTAINS AND BLINDS
- RECESSED LED DOWN LIGHT
- PENDANT LIGHTING
- EXIT LIGHT MAINTAINED CENTRAL BATTERY TYPE
- EMERGENCY LIGHT NON MAINTAINED  
CENTRAL BATTERY TYPE
- EMERGENCY LIGHT NON MAINTAINED SELF CONTAINED  
TYPE WITH INTERNAL BATTERY/ INVERTER UNIT  
3 HOUR BATTERY
- MOTION & PRESENCE SENSOR  
WITH 60 MINUTES ADJUSTABLE TIME DELAY
- 360° MOTION & OCCUPANCY SENSOR
- AIR CONDITIONING UNIT WITH 13A FSU
- ADDRESSABLE SMOKE DETECTOR
- CLOSE CIRCUIT TV CAMERA
- LOUDSPEAKER
- PENDENT LIGHT
- EMERGENCY LIGHT
- LOBBY LIGHT
- WALL LIGHT
- STAIRCASE EMERGENCY LIGHTING
- 13A FUSE SPUR UNIT



WKK Architects Ltd.  
Park House, North Street  
Nicosia, 2411 1004  
Cyprus 2400001  
design@wkkarchitects.com  
www.wkkarchitects.com  
tel: +44(0) 1463284065

Client: Arterios  
10 Tefkenou Avenue Street  
Deli Industrial Zone  
P.O. Box 21003, 1011 Nicosia  
Tel: +357 22 741300  
Fax: +357 22 741400  
email: carterios@cytel.com

Structural Engineering:

Local Structural Engineering:

\\Logos\\JPG\_WHITE.JPG

\\Logos\\EV\\RPIIDU.JPG

\\Logos\\Logo-2015.jpg

Mechanical & Energy Engineering:

Electrical Engineering:

**YANTIS**  
ENGINEERS  
118 Managou Av. 103 42,  
2027 Paphos, Cyprus  
Tel: +357 20051000  
Fax: +357 20051000  
info@yantis-engineering.gr  
www.yantis.gr

**EBB**  
electrical engineering consultants  
09800 Smea Cmg Met. Area, MCSE  
(B778 800004)  
P.O. Box 52040  
10711 Columbia  
Tel: 202-775-1550  
Fax: 202-775-1550  
www.ebb-engineers.com

Interior Designer:

Fire Engineering:

**YANTIS**  
ENGINEERS  
118 Managou Av. 103 42,  
2027 Paphos, Cyprus  
Tel: +357 20051000  
Fax: +357 20051000  
info@yantis-engineering.gr  
www.yantis.gr

**IFC**  
Fire Protection Consultants  
10, 11 & 12 Street  
Tel: +357 22 524447  
www.ifc.com

GENERAL NOTES

- THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECTURAL & STRUCTURAL DRAWINGS.
- THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT BUILDING SERVICES DRAWINGS & THE RELEVANT SECTIONS OF THE SPECIFICATIONS & SCHEDULES.
- THIS DRAWING IS NOT SCALED.
- ALL DIMENSIONS ARE IN MM UNLESS OTHERWISE STATED.
- THE DRAWING DOES NOT INDICATE THE PRESENCE OF ALL SERVICES AND IS TO BE READ IN CONJUNCTION WITH THE MECHANICAL SERVICES SPECIFICATION AND DRAWINGS.
- ANY DISCREPANCY BETWEEN ELEMEC-GBC M&E DESIGN DOCUMENTATION, ARCHITECTS LAYOUTS AND STATUTORY REGULATIONS REQUIRE IMMEDIATE NOTIFICATION TO THE ENGINEER.
- THE ELECTRICAL INSTALLATIONS SHALL BE CARRIED OUT IN ACCORDANCE WITH THE IET WIRING REGULATIONS BS 7671: 2008 (17th EDITION, 3rd AMENDMENT - 2015, TO BE IN FORCE IN CYPRUS IN 2017), THE ELECTRICITY AUTHORITY OF CYPRUS AND THE ELECTROMECHANICAL SERVICES DEPARTMENT OF THE MINISTRY OF COMMUNICATIONS AND WORK STATUTORY REGULATIONS ALL IN ACCORDANCE TO THE RELEVANT EN, CEN, CENELEC (EU), CYS, IEC REGULATIONS AND ISO QUALITY STANDARDS.
- POWER SUPPLIES & CONTROLS FOR THE HVAC FAN COIL UNITS & U/F HEATING WILL BE AS PER MECHANICAL DESIGNS. ONLY THE APARTMENTS AIR CONDITIONING SYSTEM SHALL BE REMOTELY OPERATED FROM THE APARTMENTS SMART TOUCH SCREEN.
- PROVIDE SEPARATE 20mm PVC EMPTY CONDUIT FROM EACH BEDROOM, LOUNGE, KITCHEN AND BATHROOMS THROUGH TO THE SYSTEM CUPBOARDS FOR THE LOUD SPEAKERS AND VOLUME CONTROL OF THE AUDIO AND VISION SYSTEMS.
- ALL ELECTRICAL CABLING AND WIRING OF THE APARTMENTS LIGHTING, POWER AND SYSTEMS OUTLETS AND CONTROL DEVICES SHALL BE INSTALLED IN UPVC CONDUITS THROUGH THE FALSE CEILINGS AND PARTITION WALLS OR BRICK WALLS AND NOT THROUGH THE FLOOR SCREEDS.
- PROVISION FOR FACADE LIGHTING 24 V FROM FACADE DB (THE LIGHTING CONTROL SHALL BE FROM THE COMMONS CENTRAL LIGHTING CONTROL). THE FINAL DESIGN SHALL BE PROVIDED FOLLOWING THE LIGHTING DESIGNERS DRAWINGS.

